

Issued: February 15, 2011


**To all Users of the Water System Standards:**

The following changes, additions, and/or deletions are hereby made a part of the *Water System Standards* dated March 20, 2002 for projects designed for installation in the Tualatin Valley Water District's system, as fully and completely as if the same were set forth therein.

There is 1 page included in this Addendum No. 2. This is page 1.


The effective date for incorporating these changes is February 15, 2011.

Approved:



Mark Knudson, P.E.  
Chief Engineer

Authorized:



Gregory E. DiLoreto  
General Manager

**ADDITION OF ACCEPTABLE GATE VALVE MANUFACTURER:**

Section "**VALVES AND VALVE BOXES**"; under subsection "GATE VALVES" add American AVK Company to the list of allowable manufacturers providing gate valves for installation in the District's facilities.

**CUSTOMER SERVICE LINES:**

Section "**WATER SERVICE CONNECTIONS**"; at the end of subsection "**B. MATERIALS**" add the following:

**"CUSTOMER SERVICE LINES**

The customer service line begins at the outlet of the District supplied meter assembly with a connection to the fitting projecting from the back of the meter. Only commonly used water pipe and fittings constructed of brass, copper, cast iron, PVC, galvanized malleable iron, PEX, or other materials as approved under applicable plumbing and other specialty codes shall be connected to the meter assembly. All valves and other devices installed on the customer service line beyond the meter shall be located a minimum of 3-feet beyond the outlet of the meter assembly.

