



KEYNOTES:

- A. NORMALLY CLOSED VALVE
  - A.1. VALVE SIZE SHALL MATCH MAINLINE SIZE
  - A.2. ALL JOINTS SHALL BE RESTRAINED
  - A.3. SEE DETAIL 402 FOR VALVE BOX REQUIREMENTS
- B. LINE-SIZE X 2" THREADED TEE
- C. 2" BLOWOFF ASSEMBLY; SEE DETAIL 306
- D. MOVE TO OPPOSITE SIDE IF 12" MINIMUM IS NOT MAINTAINED
- E. 2" X 6" BRASS NIPPLE

ALTERNATIVE METHOD:

- F. LINE-SIZE X 4" MJ TEE
- G. 4" MJ PLUG WITH OFFSET 2" TAP AT BOTTOM



**TUALATIN VALLEY**  
WATER DISTRICT

DESIGNED: MBA

APPROVED: NWA

SCALE: NONE

**2" BLOWOFF ASSEMBLY  
AT NORMALLY CLOSED  
PRESSURE ZONE BREAK**

DATE: 11/2019

DETAIL

**305**